

To: All Potential Offerors
From: Gary Prosocki, Procurement Specialist
Date: June 22, 2022
Subject: RFP 467-22, Temperature Monitoring

Please add this Addendum #1 to the original RFP documents. It shall be the responsibility of the interested Offerors to adhere to any changes or revision to the RFP as identified in this Addendum #1.

The following questions, and our responses, received as of 6/20/2022, shall be made a part of the procurement file:

Question: Our sensors support 802.11b, g, on single stream on 2.4 GHz today and note that we differ from your requirement on 5GHz, 802.11r protocol. Our competitive records indicate a gap in 5GHz in the market currently, though it is on our roadmap for a next generation sensor type that would be provided under our hardware assurance program. Response: The intent is to have a FOQA program approved by the FAA—and that it be described.

Response: We will accept 2.4Ghz on 802.11 G and N only. It must support WPA 2 Enterprise suite.

Question: Our solution does not support 5Ghz Wi-Fi, however we support 2.4Ghz WPA2 Enterprise with DHCP and multiple security protocols. Will UNM consider a proposal that does not meet this spec while supporting WPA2 security on 2.4Gh.

